

Verification of Conformity

On the basis of the evaluations undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address : Tesla, Inc.
Product(s) Tested : 3500 Deer Creek Rd, Palo Alto, CA 94304 USA
Ratings and principal characteristics : 100/200V, 230V, 240V; 50/60Hz
Model(s) : Backup Gateway 2.0
Brand name : Tesla
Relevant Standard(s)/Specification(s) : IEC 61439-3:2012 for use in conjunction with IEC 61439-1:2011
Verification Issuing Office Name & Address : Intertek Testing Services Inc
3933 US Route 11,
Cortland, NY 13045 USA
Date of Test(s) : 03/04/2019
Verification/Report Number(s) : 103396146CRT-040

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Signature

Name: Ang Zhu
Position: Team Lead
Date: 03/12/2019

Summary of testing:

<p>Tests performed (name of test and test clause):</p> <p>10.9.4 Testing of enclosures made of insulating material</p> <p>10.2.3.1 Verification of thermal stability of enclosures</p> <p>10.2.6 Mechanical Impact – References IEC60068-2-75</p> <p>10.11 Short-circuit withstand strength</p>	<p>Testing location:</p> <p>Tesla Inc. 3500 Deer Creek Rd, Palo Alto, CA 94304 & 47400 Kato Road, Fremont, CA 94538</p> <p>Schneider Lab address 3700 6th St SW, Cedar Rapids, IA 52404</p>
--	--