

Certificate of compliance

Applicant:

Huawei Technologies Co., Ltd Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District, Shenzhen, Guangdong, 518129, China

Product: Photovoltaic (PV) inverter

Model: SUN2000-100KTL-M2 SUN2000-115KTL-M2

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2014 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

IEC 61727:2004

Photovoltaic (PV) systems - Characteristics of the utility interface

IEC 62116:2008 / IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	PV2208WDG0121-1 PV2208WDG0121-2	Certification program:	NSOP-0032-DEU-ZE-V01
Certificate number:	U22-0565	Date of issue:	2022-09-23
	LER FL	Georg Loritz	DAKKS Deutsche Akkreditierungsstelle D-ZE-12024-01-00
Certification body Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065			
Testing laboratory accredited according to DIN EN ISO/IEC 17025			
A partial representatior	n of the certificate requires the writte	en approval of Bureau Veritas Consumer Produ	ucts Services Germany GmbH