

IEC**IECEE**

®

TM

Ref. Certif. No.

JPTUV-136000

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Grid-connected PV Inverter
Name and address of the applicant	Sungrow Power Supply Co., Ltd. No.1699 Xiyou Rd.,New & High Technology Industrial, Development Zone, Hefei, 230088 Anhui, P.R. China
Name and address of the manufacturer	Sungrow Power Supply Co., Ltd. No.1699 Xiyou Rd.,New & High Technology Industrial, Development Zone, Hefei, 230088 Anhui, P.R. China
Name and address of the factory	Sungrow Power Supply Co., Ltd. No.1699 Xiyou Rd.,New & High Technology Industrial, Development Zone, Hefei, 230088 Anhui, P.R. China
Ratings and principal characteristics	SG125CX-P2/ SG110CX-P2/ SG75CX-P2 Input : 180-1000 Vdc, 30*12A/30*12A/30*8A; Output: 3/N/PE 230/400Vac, 181.1A/167.1A/113.9A, 125kW/110kW/75kW
Trademark (if any)	Sungrow
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	SG125CX-P2/ SG110CX-P2/ SG75CX-P2
Additional information (if necessary may also be reported on page 2)	Detail information refer to test report CN22830E 001
A sample of the product was tested and found to be in conformity with	IEC 62109-2:2011 IEC 62109-1:2010 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22830E 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2022-06-06

Signature:

Weichun Li